

Call 02 Mill & Overlay approximately 13 miles of US 45 from Lowndes County Line to just north of SR 25, known as Federal Aid Project No. STP-0002-05(072) / 107174301 in Monroe County.

Q1. In the proposal on sheets, 149, 150 and 151 it shows loose rock signs, will these signs be used anywhere on the job? Is there any seal work on job or is it just a mill and overlay?

A1. SBST is required on the shoulders of the ramps of HWY 45 and HWY 25 Intersection as shown on TS-2 of the Plans. However, "Loose Rock" signs **will not** be required.

Q2. Will you require the contractor to haul the vegetation material off site or will placing it on the slope be adequate?

A2. Vegetation that has been removed can be placed on the slope. However, any root balls or clods must be busted up or bush hogged in order to blend in with the slope.